

APPENDIX A.

SECTION 2

CITY OF HUDSON

**PHOTOVOLTAIC/ENERGY STORAGE SYSTEM GENERAL
REQUIREMENTS**

- I. PV System Output Size
 - A. Residential
 - 1. Maximum 25kW
 - B. Commercial/Industrial
 - 1. Maximum 200kW

NOTE: Requests for Commercial / Industrial system interconnections that exceed the 200kW output limit will be considered and evaluated as to the feasibility of the request on a case-by-case basis and approved by Hudson Public Power.

- II. PV Inverter Output Voltage (AC)
 - A. 240 VAC nominal residential
 - B. 208/240/480 VAC commercial
- III. PV System Standards
 - A. NEC 690, IEEE 1547, UL1741, UL1703, ANSI & NESC along with all applicable 30kW