



SHAWN KASSON  
Fire Marshal

[skasson@hudson.oh.us](mailto:skasson@hudson.oh.us)  
(330) 342-1869

# M E M O R A N D U M

**DATE:** July 8, 2025

**TO:** Nick Sugar, City Planner

**FROM:** Shawn Kasson, Fire Marshal SK

**SUBJECT:** Christ Community Chapel – Office Addition – 750 West Streetsboro Street

I have reviewed the site plan set dated 06/13/25 for the proposed office addition at Christ Community Chapel – 750 West Streetsboro Street. Upon review I have the following comments:

- The utility plan indicates that the proposed fire department connection (FDC) piping terminates at the building foundation of the office addition. Provide explanation/details of piping continuation for interconnection at sprinkler system riser.
- The access drive in front of the FDC and fire hydrant is designated as a fire lane.
- Fire lane areas must be identified with approved signage stating *Fire Lane – No Parking*.
- Curbs in fire lane areas must be painted red in color.
- The FDC riser piping must be painted red in color.
- The FDC must be identified with an approved sign stating *FDC*.

Please contact me with any questions.